

## SECTION NOT TO SCALE

## NOTES:

- 1. 8" PRV STATION SHOWN. 6" PRV STATION IS IDENTICAL EXCEPT THE UPSTREAM AND DOWNSTREAM PIPING, FITTINGS, AND VALVES ARE 6".
- 2. PAINT ALL EXPOSED PIPING AND FITTINGS WITHIN VAULT AND ABOVE GRADE.
- 3. ALL VALVES INSIDE VAULT TO HAVE HAND WHEEL OPERATORS.

APPROVED: SCOTT THOMASSON

WATERWASTEWATER DIVISION

REV. DATE: NOV. 01, 2005





STANDARD DETAILS

6" AND 8" PRV STATION SECTION

FILE SD709B.DGN DRAWING NO.

709B